Acoustic Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Product Description	BUDGET-FIREPAN
Test Reference	BTC 17782A
Date	7th June 2012
Report Number	H17782DA
Methodology	Laboratory Measurement to BS EN ISO 717-1:1997
Acoustic Reduction (f, Hz 100-3150)	36dB
Test Centre	The Building Test Centre British Gypsum East Leake Loughborough Leics. LE12 6NP Tel (0115) 945 1564 Fax (0115) 945 1562 email btc.testing@saint-gobain.com

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.