Acoustic Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

Product Description	PFFD-INS-AT 600
Test Reference	WYC389347/P001
Date	27th September 2017
Report Number	BMT/WYC389347
Methodology	Laboratory Measurement to BS EN ISO 10140-2 (Airborne Sound Insulation)
Acoustic Reduction (f, Hz 100-3150)	36dB

Test Centre

Exova (UK) Ltd, Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND

Tel (0149) 456 9800
Website www.exova.com

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.