Acoustic Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Product Description	SDS-BESPOKE-LOFTHATCH
Test Reference	WYC389347/P001
Date	27th September 2017
Report Number	PFFD-INS-AT 600
Methodology	Laboratory Measurement to BS EN ISO 10140-2 : 2010
Acoustic Reduction (f, Hz 100-3150)	36dB
Test Centre	Exova Chiltern House Stocking Lane Hughenden Valley High Wycombe Buckinghamshire HP14 4ND Tel (0192) 565 5116 email cathryn.cooper@bmtrada.com

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.