

Fire Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Product Description SDS-FR 900×900mm

Date 12th May 2021

Report Number BTC 21625F

Methodology BS 476: Part 22: 1987

Panel Position Ceiling

Fire Duration 91 Minutes.

Test Centre The Building Test Centre
British Gypsum
East Leake
Loughborough
Leics. LE12 6NP
Tel (0115) 945 1564
Fax (0115) 945 1562
email btc.testing@saint-gobain.com

Access Building Products Ltd

Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk

T: 01423 874753

Mon-Thurs 8.30-5.00

Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.

This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.

The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

The original documents are intellectual property of the Access Building Products Ltd.

