Smoke Test Certificate

Access Building Products Ltd
has commissioned the following test on:

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

Product Description	ANTI-LIG 800×2050MM
Test Reference	WYC438136/02
Date	31st March 2021
Report Number	N/A
Methodology	Laboratory Measurement to BS EN 1634-3: 2004

Leakage Rate (25Pa)	**Positive Chamber ($m^3/m/h$)**	**Negative Chamber ($m^3/m/h$)**
	0.50	0.64

Test Centre

Warringtonfire
Holmsfield Rd, Warrington WA1 2DS
Tel (01925) 541 269
email: www.warringtonfire.com/contact-us/quote

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.