U-Value Calculation

Access Building Products Ltd
has calculated the following U Value on:

Product Description	AT35
Test Code	AT35/C
Date	12th May 2023
Methodology	BS EN ISO 6946
U Value	0.35

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.

U-Value Calculation

Access Building Products Ltd
has calculated the following U Value on:

Product Description	PD25
Test Code	PD25/C
Date	12th May 2023
Methodology	BS EN ISO 6946
U Value	0.25

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.

U-Value Calculation

Access Building Products Ltd
has calculated the following U Value on:

Product Description	PD15
Test Code	PD15/C
Date	12th May 2023
Methodology	BS EN ISO 6946
U Value	0.15

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.
This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.
The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

ACCESS BUILDING PRODUCTS LTD

The original documents are intellectual property of the Access Building Products Ltd.