

U-Value Calculation

Access Building Products Ltd
has calculated the following **U Value** on:

Product Description External Electricity Meter Box
Test Code EMB/C
Date 12th May 2023
Methodology BS EN ISO 6946
U Value 0.35

Access Building Products Ltd
Registered Office
Unit 86 Marston Moor Business Park,
Tockwith, YO26 7QF

E: info@accessbuildingproducts.co.uk
T: 01423 874753

Mon-Thurs 8.30-5.00
Fri 8.30-4.30

Reg No 5952723

A large, light green stylized logo consisting of the letters 'U' and 'V' joined together, enclosed within a thin grey circular border. The 'U' and 'V' are rendered in a bold, sans-serif font.

This certification is representative of the original document generated by the actual test certificate produced by the UKAS-Accredited Test Laboratory documented above, for the product detailed above.

This certificate is created to provide sufficient information for the user to evaluate the suitability of the introduced product.

The full UKAS-Accredited Test Report linked to this certificate is available by contacting our offices during the opening hours above.

The original documents are intellectual property of the Access Building Products Ltd.

